



GENERAL NOTES

1. IF DOOR IS TO BE GROUTED, GROUT ONLY TO LEVEL OF TOP FRAME MEMBER, MAKING SURE EPT-10 MORTAR BOX IS IN PLACE, PIPED & SEALED.
2. IF DOOR IS TO BE EQUIPPED WITH HANDICAP ACCESS OPERATOR, THOSE ROUGH-IN PROVISIONS SHALL BE IN ADDITION TO THESE REQUIREMENTS. HANDICAP ACCESS OPERATOR SHALL HAVE CONDUIT RUN FROM ITS CONTROL PANEL TO THE DOOR ACCESS CONTROL PANEL AND INCLUDE 120V POWER.
3. IF NO ACCESSIBLE CEILING SPACE IS NEAR THE CONTROLLED DOOR, ALL CONDUITS ARE TO BE RUN CONTINUOUS TO THE DOOR ACCESS CONTROL PANEL.
4. FOR DOUBLE DOORS, DUPLICATE THE DOOR POSITION SWITCH ROUGH-IN AND ELECTRIC PASS THRU ROUGH-IN.
5. IF PATH TO DOOR ACCESS CONTROL PANEL IS THRU EXPOSED AREA, ALL CONDUITS MAY BE JOINED TOGETHER AT A DEEP 4"x4" JUNCTION BOX AND ROUTED TO THE CONTROL PANEL AS A SINGLE 3/4" CONDUIT.
6. **DOOR HARDWARE SCHEDULE DETERMINES ACTUAL ROUGH-IN REQUIREMENTS.**

1
CARD ACCESS ROUGH-IN DETAIL

A1.01 SCALE: NO SCALE

Detail Title: <p style="text-align: center;">Card Access Rough-In Detail</p>	Detail No.: 28 10 00 - 01 Scale: N.T.S. Date: October 2020	Facilities Planning & Construction Standard Detail	
---	--	---	--