


**MECHANICAL EQUIPMENT BASE NOTES**

1. FLOOR UNDER BASE SHALL BE ROUGHENED, BASE SHALL BE DOWELED TO FLOOR. ADJUST BASE SIZE AS REQUIRED FOR INDIVIDUAL EQUIPMENT INSTALLED.
2. ALL BASES SUPPORTING BOTH EQUIPMENT AND A CONCRETE INERTIA PAD SHALL BE REINFORCED AS FOLLOWS:
  - PROVIDE #5 REBAR @ 12" O.C. BOTH WAYS IN BASE

1
**MECHANICAL EQUIPMENT BASE**  
 A1.01 SCALE: NO SCALE

Detail Title:  <b>MECHANICAL EQUIPMENT BASE</b>	Detail No.: 03 30 53 - 01  Scale: N.T.S.  Date: October 2020	Facilities Planning & Construction Standard Detail	
---	--	---	---